

**APPROVAL OF ELECTRICAL APPARATUS & CABLES UNDER REGULATION
75(2) OF THE OIL MINES REGULATIONS, 1984**

The list of approved cable is not exhaustive and subject to verification of the approval documents.

Sl. No.	Description of cables	Name of Manufacturer (M/S)	Approval no.	Valid upto
P1	1.1 KV copper conductor PVC insulated, PVC sheathed single wire armoured control and instrumentation cables upto and including (1) 19 Core X 2.5 mm ² (2) 24 Pair X 1.5 mm ² and (3) 8 Triad X 1.5 mm ² manufactured by M/S Polycab Wires Pvt. Ltd., Mumbai conforming to IS:1554(Part-I)-1988 for use in Zone 1 and Zone 2 hazardous areas in Oil Mines.	Polycab Wires Pvt. Ltd. 1 st Floor, HICO House 771 Pandit Satwalekar Marg Mahim, Mumbai-400 016.	01 of 2009	18.02.1010
P2	1.1 KV copper conductor PVC insulated, PVC sheathed single wire armoured cable upto and including 2 core X10 mm ² manufactured by M/S Polycab Wires Pvt. Ltd., Mumbai conforming to IS:1554(Part-I)-1988 for use in Zone 1 and Zone 2 hazardous areas in Oil Mines.	Polycab Wires Pvt. Ltd. 1 st Floor, HICO House 771 Pandit Satwalekar Marg Mahim, Mumbai-400 016.	02 of 2009	18.02.1010
P3	1.1 KV copper conductor PVC insulated, PVC sheathed, single wire armoured cables upto and including (1) 3 Core X 95 mm ² (2) 3.5 Core X 300 mm ² and (3) 4 Core X 16 mm ² manufactured by M/S Polycab Wires Pvt. Ltd., Mumbai conforming to IS:1554(Part-I)-1988 for use in Zone 1 and Zone 2 hazardous areas in Oil Mines.	Polycab Wires Pvt. Ltd. 1 st Floor, HICO House 771 Pandit Satwalekar Marg Mahim, Mumbai-400 016.	03 of 2009	18.02.1010